



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: IECEx PTB 14.0038X Issue No: 0 Certificate history:
Issue No. 0 (2017-08-07)

Status: **Current**

Date of Issue: **2017-08-07** Page 1 of 3

Applicant: **ROSE Systemtechnik GmbH**
Erbeweg 13 - 15
32457 Porta Westfalica
Germany

Equipment: **Power distribution, switch and control gear assembly out of aluminium
type 90. XX XX XX**

Optional accessory:

Type of Protection: **different**

Marking:
Ex eb db mb ia [ia Ga] nA nC [op is] IIC T6, T5, T4 Gc
Ex tb IIIC T85 °C, T100 °C, T135 °C Db

Approved for issue on behalf of the IECEx
Certification Body:

Dr. Ing. Detlev Markus

Position:

Head of Working Group "Explosion Protection in Energy Technology"

Signature:
(for printed version)

D. Markus
18.08.17

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

Physikalisch-Technische Bundesanstalt (PTB)
Bundesallee 100

38116 Braunschweig
Germany



Physikalisch-Technische Bundesanstalt



IECEX Certificate of Conformity

Certificate No: IECEX PTB 14.0038X Issue No: 0

Date of Issue: 2017-08-07 Page 2 of 3

Manufacturer: **ROSE Systemtechnik GmbH**
Erbeweg 13 - 15
32457 Porta Westfalica
Germany

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Edition:6.0	Explosive atmospheres - Part 0: General requirements
IEC 60079-1 : 2014-06 Edition:7.0	Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
IEC 60079-11 : 2011 Edition:6.0	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
IEC 60079-15 : 2010 Edition:4	Explosive atmospheres - Part 15: Equipment protection by type of protection "n"
IEC 60079-18 : 2014 Edition:4.0	Explosive atmospheres - Part 18: Equipment protection by encapsulation "m"
IEC 60079-28 : 2015 Edition:2	Explosive atmospheres - Part 28: Protection of equipment and transmission systems using optical radiation
IEC 60079-31 : 2013 Edition:2	Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

[DE/PTB/ExTR14.0045/00](#)

Quality Assessment Report:

[DE/EPS/QAR17.0003/02](#)



IECEX Certificate

Certificate No: IECEx PTB 14.0038X

Issue No: 0

Date of Issue: 2017-08-07

Page 3 of 3

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The power distribution, switch and control gear assembly, type 90. XX XX XX, consists of an aluminium enclosure designed to

COCA140038-00.pdf



Applicant: ROSE Systemtechnik GmbH
Erbeweg 13-15
32457 Porta Westfalica
Germany

Electrical Apparatus: Power distribution, switch and control gear assembly out of aluminium type 90. XX XX XX

Description

The power distribution, switch and control gear assembly, type 90. XX XX XX, consists of an aluminium enclosure designed to Increased Safety "e" or Protection by Enclosure "tb" type of protection, which can be provided with flanges, if necessary.
It is used to accommodate field bus distributors and terminals, and can be provided with actuator elements and pilot lamps, if necessary.

Ex cable glands are used for connection

All installed and attached components are tested and certified with a separate examination certificate.

Technical data:



No.	Enclosure Type	Height [mm]	Width [mm]	Depth [mm]	No.	Enclosure Type	Height [mm]	Width [mm]	Depth [mm]
1.	90.06 06 03	64	58	34	21.	90.16 56 09	160	560	91
2.	90.06 10 03	64	98	34	22.	90.18 18 10	180	180	101
3.	90.06 15 03	64	150	34	23.	90.18 28 10	180	280	101
4.	90.08 08 06	80	75	57	24.	90.23 10 11	230	100	111
5.	90.08 13 06	80	125	57	25.	90.23 20 11	232	202	111
6.	90.08 18 06	80	175	57	26.	90.23 20 18	232	202	181
7.	90.08 25 05	80	250	52	27.	90.23 28 11	230	280	111
8.	90.10 10 08	100	100	81	28.	90.23 33 11	230	330	111
9.	90.10 16 08	100	160	81	29.	90.23 33 18	230	330	181
10.	90.10 20 08	100	200	81	30.	90.23 40 11	230	400	111
11.	90.12 12 08	120	122	81	31.	90.23 40 23	230	400	225
12.	90.12 12 09	120	220	91	32.	90.23 60 11	230	600	111
13.	90.12 22 08	120	220	81	33.	90.31 40 11	313	404	111
14.	90.12 22 09	120	220	91	34.	90.31 40 14	312	403	141
15.	90.12 36 08	120	360	81	35.	90.31 40 18	313	404	181
16.	90.14 14 09	140	140	91	36.	90.31 40 23	313	404	227
17.	90.14 20 09	140	200	91	37.	90.31 60 11	310	600	111
18.	90.16 16 09	160	160	91	38.	90.31 60 18	310	600	181
19.	90.16 26 09	160	260	91	39.	90.60 60 20	600	600	202
20.	90.16 36 09	160	360	91					

Max. Power Dissipation of Aluminium Enclosures

Gehäuse Typ Enclosure Type	Max. Verlustleistung Max. Power Dissipation [Watt]	Gehäuse Typ Enclosure Type	Max. Verlustleistung Max. Power Dissipation [Watt]
25.06 06 03	5.7	25.16 56 09	107.1
25.06 10 03	8.3	25.18 18 10	49.8
25.06 15 03	11.8	25.18 28 10	68.7
25.08 08 06	10.9	25.23 10 11	45.1
25.08 13 06	15.5	25.23 20 11	68.9
25.08 18 06	20.1	25.23 20 18	92.5

Additional Advices

The empty enclosure with a coating must not be used in areas affected by charge producing

