



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION
IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Ex COMPONENT CERTIFICATE

Certificate No.: IECEx DEK 18.0071U Page 1 of 3 [Certificate history:](#)

Status: Current Issue No: 0

Date of Issue: 2019-11-14

Applicant: ROSE Systemtechnk GmbH
Erbeweg 13 - 15
32457 Porta Westfalica
Germany

Ex Component: Enclosure Series GUB

This component is NOT intended to be used alone and requires additional consideration when incorporated into other equipment or systems for use in explosive atmospheres (refer to IEC 60079-0).

Type of Protection: Ex db, Ex tb

Marking: Ex db IIB Gb or Ex db IIC Gb
Ex tb IIIC Db

Approved for issue on behalf of the IECEx
Certification Body:

R. Schuller

Position:

Certification Manager

Signature:
(for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands





IECEX Certificate of Conformity

Certificate No.: IECEx DEK 18.0071U Page 2 of 3

Date of issue: 2019-11-14 Issue No: 0

Manufacturer: ROSE Systemtechnk GmbH
Erbeweg 13 - 15
32457 Porta Westfalica
Germany

Additional manufacturing locations: Phoenix Mecano (India) Pvt. Ltd. Plant - I & II:
Pirangut Industrial Area, Post Ghotowade,
Plot 388/389, Village Bhare, Taluka Mulshi
Disit, Pune - 412 115
India

PM Komponenten B.V.
Havenstraat 100
7005 AG Doetinchem
Netherlands

See Annex 2 for all manufacturing locations

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

IEC 60079-1:2014-06 Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
Edition:7.0

IEC 60079-31:2013 Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
Edition:2

This Certificate does not indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

[NL/DEK/ExTR19.0093/00](#)

Quality Assessment Report:

[DE/EPS/QAR17.0003/16](#)



IECEx Certificate of Conformity

Certificate No.: IECEx DEK 18.0071U

Page 3 of 3

Date of issue: 2019-11-14

Issue No: 0

Ex Component(s) covered by this certificate is describe below:

Enclosures Series GUB, made of aluminium, stainless steel or cast iron with a threaded cover, with or without display window, are intended to be used in potentially explosive atmospheres for the mounting of electrical apparatus such as terminals, switching-, control-, regulating-, measuring- and indicating devices.

The electrical connections are made by using separately certified cable glands or conduit entries.

Service temperature range:

- GUB 01 ... GUB 06: -20 °C to +130 °C
- GUB 01W ...GUB 06W: -20 °C to +95 °C

Degree of protection IP66 according to IEC 60529 and IEC 60079-0.

For more detailed information, see Annex 1.

SCHEDULE OF LIMITATIONS:

1. The application of the GUB enclosures shall be in accordance with the specified temperature limits.
2. For enclosures provided with a powder coating or liquid painting and intended for use in Group III applications, the user shall minimize the risk from electrostatic discharge by suitable selection and installation.
3. The maximum number of apertures, their maximum sizes and their positions are specified in the instruction manual IM.GUB.U
4. Oil-filled circuit-breakers and contactors shall not be used.
5. The content of the GUB enclosure may be placed in any arrangement provided that an area of at least 20 % (Group IIB) or 40 % (Group IIC) of each cross-sectional area remains free. Separate relief areas may be aggregated provided that each area has a minimum dimension in any direction of 12.5 mm.
6. The threaded flame path of the cover is more than required by IEC 60079-1. Contact the manufacturer for information on the dimensions of the flameproof joints.

Annexes:

[222966700 Annex 1.pdf](#)

[222966700 Annex 2.pdf](#)

Annex 2 to Certificate of Conformity IECEx DEK 18.0071U

Manufacturing locations

Rose Sysiuiok18(7(G-5(mu)7(fb3(e HETBT1 0 0 1 183.62 790824 Tm[Ros)-4(ETBT1 0 0 1 68.064 21.024 693.46Ros)-