



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: IECEx CES 18.0007X

Issue No: 0

Certificate history:

Issue No. 0 (2018-03-19)

Status: **Current**

Page 1 of 3

Date of Issue: **2018-03-19**

Applicant: **Rose Systemtechnik GmbH**
(A Phoenix Mecano Company)
Erbeweg no:13-15
D-32457 Porta Westfalica
Germany

Equipment: **Cable glands, series CGA**, CGU**, MCGU**, CGA**LT****

Optional accessory:

Type of Protection: **Flameproof enclosures 'd'; Increased safety 'e'; Dust ignition protection 't'**

Marking:

Ex db IIC Gb and Ex db IIC Gb

or

Ex db IIC Gb and Ex db IIC Gb

Signature:
(for printed version)

Date:

Roberto Piccin
19-3-2018

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

CESI
Centro Elettrotecnico
Sperimentale Italiano S.p.A.
Via Rubattino 54
20134 Milano
Italy

CESI **CESI** S.p.A.
Testing & Certification Division
Business Area Certification
Il Responsabile
(Roberto Piccin)

P. AD. 13006279 (2199410) - USD RISERVATO



IECEX Certificate of Conformity

Certificate No: IECEX CES 18.0007X Issue No: 0

Date of Issue: 2018-03-19 Page 2 of 3

Manufacturer: **Rose Systemtechnik GmbH**
(A Phoenix Mecano Company)
Erbeweg no:13-15
D-32457 Porta Westfalica
Germany

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

| | |
|---|--|
| IEC 60079-0 : 2011 Edition:6.0 | Explosive atmospheres - Part 0: General requirements |
| IEC 60079-1 : 2014-06 Edition:7.0 | Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d" |
| IEC 60079-31 : 2013 Edition:2 | Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t" |
| IEC 60079-7 : 2015 Edition:5.0 | Explosive atmospheres – Part 7: Equipment protection by increased safety "e" |

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

IT/CES/ExTR18.0007/00

Quality Assessment Report:

DE/ERS/QAR17.0003/04



IECEX Certificate of Conformity

Certificate No: IECEx CES 18.0007X

Issue No: 0

Date of Issue: 2018-03-19

Page 3 of 3

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The series of cable glands with trade mark Rose Systemtechnik GmbH is composed by the following types: CGU**, MCGU**, CGA** and CGA**LT** cable glands.

The cable glands series CGU**, MCGU**, CGA** and CGA**LT** are suitable for inserting circular cables into Ex db enclosures having threaded entries and Ex eb or Ex tb enclosures having either threaded or plane entries. Attachment of the glands to an enclosure is by means of the male threaded portion on the male body.

The types CGU** and MCGU** glands are designed for non-armoured cables and are comprised of a male body, inner sealing ring, pressure ring and cap.

The Standard types CGA** and CGA**LT** cable glands are suitable for steel wire armoured cables. They are comprised of a male body, lower sealing ring, grounding cone, swivel braid retainer, middle body, upper sealing ring and cap.

For Universal types CGAU** and CGAU** LT** cable glands the armour reduction ring is used. With this additional ring, they can be used for shielded cables. When the armour reduction ring is taken out, then they can be used for armoured cables. While Offshore types CGAO** and CGAO**LT** cable glands are suitable for steel wire armoured cables and are comprised of a male body, lower sealing ring, grounding cone, swivel braid retainer, middle body, upper sealing ring and cap.

The cable glands characteristics are further described in the Annexe of this certificate.

SPECIFIC CONDITIONS OF USE: YES as shown below:

- The coupling of the cable glands with the enclosures shall be made as indicated by the manufacturer in the documents annexed to this certificate in order to respect the type of protection of the electrical apparatus on which cable glands are mounted.
- The cable glands shall be mounted at the electrical apparatus in such a way that accidental rotation and loosening will be prevented.
- The CGA**, CGA**LT** and MCGU** cable glands types have to be protected from hydraulic fluids, oils and greases when applied for Group I (mines) applications.
- The CGA** (Standard) cable glands types from M20x1.5 up to M90x1.5 sizes and CGA**LT** (Standard) cable glands types all sizes are only admitted for Group I applications.
- The MCGU** cable glands types M16x1.5 sizes are not admitted for Group I applications.
- The CGA** cable glands types made of Aluminium alloy are not admitted for Group I applications and are available from M25x1.5 up to M75x1.5 sizes only.
- The cable glands shall be installed in such a way that the temperature at the mounting point will remain within the service temperature ranges accordingly to the marking.
- The degree of protection IP 66/68 according to the IEC 60529 standard will be guaranteed for the cable glands if the holes into which cable glands are mounted are suitably sealed. To this scope the correct positioning of the gaskets (for cylindrical threads) or the application of sealant on the threads (for tapered threads), shall be done as indicated in the manufacturer instruction.

Annex:

[IECEX CES 18.0007X Issue 0 ANNEX- Cable glands CGA.pdf](#)



IECEX Certificate of Conformity

CESI

Prot: B8006279

Annex to certificate: IECEX CES 18.0007X Issue No.:0 of 2018-03-19

Applicant: Rose Systemtechnik GmbH (A Phoenix Mecano Company)

Erbeweg 13-15, D-32457 Porta Westfalica – Germany

Apparatus: Cable Glands, series CGA**, CGU**, MCGU**, CGA**LT**

Description of the equipment:

The series of cable glands with trade mark **Rose Systemtechnik GmbH** is composed by the following types: **CGU****, **MCGU****, **CGA**** and **CGA**LT**** cable glands

The cable glands series **CGU****, **MCGU****, **CGA**** and **CGA**LT**** are suitable for inserting circular cables into Ex db enclosures having threaded entries and Ex eb or Ex tb enclosures having either threaded or plane entries. Attachment of the glands to an enclosure is by means of the male threaded portion on the male



IECEx Certificate of Conformity



Prot: B8006279

Annex to certificate: IECEx CES 18.0007X Issue No.:0 of 2018-03-19
Applicant: Rose Systemtechnik GmbH (A Phoenix Mecano Company)
 Erbeweg 13-15, D-32457 Porta Westfalica – Germany
Apparatus: Cable Glands, series CGA**, CGU**, MCGU**, CGA**LT**

Constructional characteristics

Service temperature ranges:

Models with sealing rings made of Chloroprene rubber: - 40 ÷ + 100 °C for types CGA**, CGU**;
 - 40 ÷ + 80 °C for type MCGU**;
 - 40 ÷ + 80 °C for type CGA**LT**.

Models with sealing rings made of Silicon rubber: - 60 ÷ + 130 °C for types CGA**, CGU**;
 - 60 ÷ + 80 °C for type MCGU**.

Types for **Group I** (mines) execution: up to + 80 °C.

Models supplied with Fiber flat washer: - 50 ÷ + 80 °C for all types.

Models made of Galvanized carbon steel: limited up to - 20 °C.

The cable gland types, installation Group, manufacturer materials and service temperature ranges are reported in the table below:

| Type | Exec. | Materials | Seals | Temperature |
|------|-------|-----------|-------|-------------|
|------|-------|-----------|-------|-------------|

Prot: B8006279

Annex to certificate: IECEx CES 18.0007X Issue No.:0 of 2018-03-19
 Applicant: Rose Systemtechnik GmbH (A Phoenix Mecano Company)
 Erbeweg 13-15, D-32457 Porta Westfalica – Germany
 Apparatus: Cable Glands, series CGA**, CGU**, MCGU**, CGA**LT**

Table 2:

| CGU** | | | | |
|----------------------|----------------------|-------------|------------------|------------------------------|
| Cable glands Type | Cable glands Size | Thread size | | Cable Dia. ranges (mm) |
| | | NPT | ISO pitch 1.5 | |
| CGU | 01.. | 3/8" | M 16 | 3-8.5 |
| CGU | 01L.. | 3/8" | M 16 | 6-12 |
| CGU | 1.. | 1/2" | M 20 | 6-12 |
| CGU | 1L.. | 1/2" | M 20 | 12-14.5 |
| CGU | 2S.. | 3/4" | M 25 | 6-12 |
| CGU | 2.. | 3/4" | M 25 | 12-16 |
| CGU | 2L.. | 3/4" | M 25 | 12-20 |
| CGU | 3S.. | 1" | M 32 | 12-20 |
| CGU | 3.. | 1" | M 32 | 15-26 |
| CGU | 4S.. | 1 1/4" | M 40 | 15-26 |
| CGU | 4.. | 1 1/4" | M 40 | 20-32 |
| CGU | 5S.. | 1 1/2" | M 50 | 22-35 |
| CGU | 5.. | 1 1/2" | M 50 | 27-41 |
| CGU | 6S.. | 2" | M 63 | 35-45 |
| CGU | 6.. | 2" | M 63 | 40-52 |
| CGU | 7S.. | 2 1/2" | M 75 | 40-52 |
| CGU | 7.. | 2 1/2" | M 75 | 45-60 |



Prot: B8006279

Annex to certificate: IECEx CES 18.0007X Issue No.:0 of 2018-03-19

Applicant: Rose Systemtechnik GmbH (A Phoenix Mecano Company)
 Erbeweg 13-15, D-32457 Porta Westfalica – Germany

Apparatus: Cable Glands, series CGA**, CGU**, MCGU**, CGA**LT**

Table 3:

| MCGU** | | | | |
|--------------|---------|-------------|---------------|------------------------|
| Cable glands | | Thread size | | Cable Dia. ranges (mm) |
| Type | Size | NPT | ISO pitch 1.5 | |
| MCGU | 01M2.. | 3/8" | M 16 | 3-8.5 |
| MCGU | 01LM1.. | 3/8" | M 16 | 6-9 |
| MCGU | 01LM2.. | 3/8" | M 16 | 9-12 |



Prot. B8006279

Annex to certificate IECEx CES 18.0007X Issue No.:0 of 2018-08-18

Applicant: Rose Systemtechnik GmbH (A Phoenix Mecano Company)
 Erbeweg 13-15, D-32457 Porta Westfalica – Germany

Apparatus: Cable Glands, series CGA**, CGU**, MCGU**, CGA**LT**

Identification of cable glands CGA**LT** type:

CGA**

(*)

LT

Code that identifies cable glands for armoured or shielded cable

Code that identifies the cable type:

- **Blank:** standard (for armoured cables only)
- **U:** universal (for armoured or shielded cables)
- **O:** offshore (for shielded cables only)

Size (see Table 4 and 5).

Type of thread:

- **N:** NPT ANSI/ASME B1.20.1
- **S:** NPSM ANSI/ASME B1.20.1
- **P:** PG DIN 40430 (assessed for Ex eb protection mode only)
- **M:** ISO 261 pitch 1.5 (pitch 2.0 for sizes M90 up to M130)
- **C:** GAS ISO 228-1

Thread size (see Table 4 and 5)

LT (Lower temperature) cable gland series

Manufacturing material:

- **B:** brass
- **BN:** nickel-plated brass
- **X:** stainless steel
- **Z:** galvanized carbon steel

Seals material:

- **C:** Chloroprene (Neoprene)
- **S:** Silicon rubber

Flat washer:

- **Blank:** none
- **WC:** with flat washer in Chloroprene



IECEx Certificate of Conformity



Prot: B8006279

Annex to certificate: IECEx CES 18.0007X Issue No.:0 of 2018-03-19

Applicant: **Rose Systemtechnik GmbH (A Phoenix Mecano Company)**
Erhvervej 13-15 D-32457 Porta Westfalica Germany

Table 4:

| CGA**LT** and CGAU**LT** | | | | | | |
|--------------------------|------|-------------|---------------|---------------|------------------------|---------------|
| Cable glands | | Thread size | | | Cable Dia. ranges (mm) | |
| Type | Size | NPT | ISO pitch 1.5 | ISO pitch 2.0 | Inner sheath | Armour sheath |
| CGA**LT | 1 | 1/2" | M 20 | - | 8.5-14.5 | 12-20 |
| CGA**LT | 2X | 3/4" | M 25 | - | 8.5-14.5 | 12-20 |
| CGA**LT | 2 | 3/4" | M 25 | - | 8.5-16 | 12-21 |
| CGA**LT | 3X | 1" | M 32 | - | 8.5-16 | 12-21 |
| CGA**LT | 9 | 3" 1/2 | - | M 90 | 70-82 | 78-90 |
| CGA**LT | 10S | 4" | - | M 100 | 80-92 | 88-100 |
| CGA**LT | 10 | 4" | - | M 110 | 90-101 | 98-110 |